



8

NAGAR PALIK NIGAM BHILAI

NIT

सांसद निधि अंतर्गत 2 नग बोर खनन निर्माण, वृन्दा नगर में वार्ड क्र.-29 विधानसभा वैशाली नगर।

AS PER P:W.D BUILDING S.O.R (01.01.2015) & ELECTRICAL S.O.R. (01.06.2020)

S.No.	PARTICULARS	QTY	UNIT
1	Boring/drilling bore well perfectly vertical for the specified depth suitable to receive required dia for casing/strainer pipe, by suitable method prescribed in IS: 2800 (part 1), including collecting samples from different strata, preparing and submitting strata chart/bore log, including hire & running charges of all equipments, tools, plants & machineries required for the job, all complete as per direction of Engineer-in-charge upto 90 metre depth below ground level. All types of soil 150 mm dia.	60.00	M
2	Boring/drilling bore well perfectly vertical for the specified depth suitable to receive required dia for casing/strainer pipe, by suitable method prescribed in IS: 2800 (part 1), including collecting samples from different strata, preparing and submitting strata chart/bore log, including hire & running charges of all equipments, tools, plants & machineries required for the job, all complete as per direction of Engineer-in-charge upto 90 metre depth below ground level. Rocky strata including Boulders. 150 mm dia.	120.00	M
3	Supplying, assembling, lowering and fixing in vertical position in bore well, ISI marked G.I. casing pipe (Plain) medium class in 4 to 7 meters length one end fitted with socket as per IS: 1239 (Part-1&Part-2) 1992 with IVth revision (Up-to-date amendments), of reputed & approved make, including required hire & labour charges, fittings & accessories, all complete, for all depths, as per direction of Engineer- in-charge.150 mm nominal dia	53.00	M
4	Structural steel work riveted or bolted or welded in built-up sections, trusses and frames work upto a height of 5m above plinth level, including cutting, hoisting, fixing in position and applying a priming coat of red oxide zinc chromate primer. For pannel Box.	110.00	kg
5	Supplying of submersible pump set for water supply system with submersible motor as per specification. 5.0 HP, three phase	2.00	Each
6	Supply of 5-7.5 HP 3 phase submersible motor starter cum control	2.00	Each
7	Supplying, laying and fixing following size submersible cable along with GI/PVC/HDFC pipe line or laid in ground etc as per specification and IS: 694 (2010). Note: Cable should be rust proof, safe from oil / Grease and under water Chemical / abrasion Resistant. 3 x 4.0 sqmm	100.00	mtr.
8	Supplying and laying following sizes one number FRLS PVC insulated/XLPE, PVC sheathed, steel armoured, aluminium conductor power cable of 1.1 KV grade direct in ground at a depth not less than 40 cm and upto 90 cm including excavation, sand cushioning, protective covering and refilling the trench etc as per specification, IS: 1554 (1988, Part 1) / IS: 7098 (1988, Part 1). 4 x 10 sq. mm.	100.00	mtr.
9	Providing and laying in trenches G.I. pipes medium class complete with G.I. fittings including excavation of trenches, refilling the same and testing of joints complete: various dia as per requiemnt	2.00	nos
			
			
	ASST. ENGINEER		SUBENGINEER
	Nagar Palik Nigam, Bhilai		Nagar Palik Nigam, Bhilai

